



# Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

**Governor Asa Hutchinson**

**Nathaniel Smith, MD, MPH, Director and State Health Officer**

Engineering Section, Slot 37

[www.healthv.arkansas.gov/enr/](http://www.healthv.arkansas.gov/enr/)

Ph 501-661-2623

After Hours Emerøency 800-554-5738

Fax 501-661-2032

December 29, 2017

RYAN HUSCHKAMANSFIELD WATERWORKSPO BOX 53MANSFIELD, AR  
72944

RE: BOIL WATER NOTICE LIFTMANSFIELD WATERWORKS - PWS ID # 509  
SEBASTIAN COUNTY

Dear Manager:

The Department of Health has released the “Boil Water” Notice issued on 12/5/2017 for the Entire System. This order was issued as a precautionary measure because of the possibility that contaminated water may have entered the distribution system as a result of damage to the water storage tank roof.

The opening in the tank roof has been patched, bacteriological samples taken on December 27, 2017 and December 28, 2017 were found to be free of bacterial contamination and a satisfactory disinfectant level has been verified throughout the distribution system. The water is therefore considered “Safe” for human consumption and the “Boil Water” notice is hereby lifted.

Sincerely,

Lance A. Jones, P.E.  
Chief EngineerEngineering Section

**MANSFIELD WATERWORKS**

# SEBASTIAN COUNTY

## PRECAUTIONARY BOIL ORDER NOTICE

LIFT DATE: FRIDAY, DECEMBER 29, 2017

FOR FURTHER INFORMATION, CONTACT  
LANCE JONES  
CHIEF ENGINEER  
ENGINEERING SECTION, (501) 661-2623

NEWS ARTICLE

FOR IMMEDIATE RELEASE

THE DEPARTMENT OF HEALTH HAS RELEASED THE “BOIL WATER” NOTICE ISSUED ON 12/5/2017 FOR THE ENTIRE SYSTEM. THIS ORDER WAS ISSUED AS A PRECAUTIONARY MEASURE BECAUSE OF THE POSSIBILITY THAT CONTAMINATED WATER MAY HAVE ENTERED THE DISTRIBUTION SYSTEM AS A RESULT OF DAMAGE TO THE WATER STORAGE TANK ROOF.

THE OPENING IN THE TANK ROOF HAS BEEN PATCHED, BACTERIOLOGICAL SAMPLES TAKEN ON DECEMBER 27, 2017 AND DECEMBER 28, 2017 WERE FOUND TO BE FREE OF BACTERIAL CONTAMINATION AND A SATISFACTORY DISINFECTANT LEVEL HAS BEEN VERIFIED THROUGHOUT THE DISTRIBUTION SYSTEM. THE WATER IS THEREFORE CONSIDERED “SAFE” FOR HUMAN CONSUMPTION AND THE “BOIL WATER” NOTICE IS HEREBY LIFTED.

THE BOIL WATER ORDER WAS DUE TO STORM DAMAGE TO THE WATER STORAGE TANK

SYSTEM PERSONNEL NOTIFIED: RYAN HUSCHKA BY: LANCE JONES ON: 12/29/2017 4:06:49 PM  
SANITARIAN NOTIFIED: DAVIS, JASON|JASON DAVIS|MICHAEL CARTWRIGHT BY: LANCE JONES ON:  
12/29/2017 4:06:49 PM